

OFFICE OF THE FIRE & EMERGENCY SERVICES MUNICIPAL COUNCIL, GONDIA (M.S.)

Ganesh Nagar, Near T.V. Center, Gondia - 441601 (M.S.)

Ph. 07182-237601 ; 230000

Fire Emergency Helpline - 101

No. GMC/FES/NOC/243026

Date 07.08.2026



To,

The Head Master,

Progressive English School,

Chulod, Gondia (M.S.)

Subject - Grant of 'Provisional No Objection'

Dear Sir,

The Provisional No Objection Certificate is hereby granted for a period of 6 months W.E.F. 19/06/2026 to 18/12/2026 to M/s Progressive English School, Chulod, Gondia, for education use. The English school is running since last 16th years in the building of Smt. Umabai Bahuuddeshiya Shikshan Sanstha, Gondia built up on T.S. No. 25, thak no. 71, Gat No. 194, mauza chulod Dist. Gondia (M.S.).

The fire protection system along with fire extinguishers and equipments has been installed in the building by the applicant, as per Indian standard hence system is found in working condition.

After compilation of installation work as you have submitted the report of completion there is No Objection to start and use of firefighting system and equipment installed at building. The building is fire and life safe.

This N.O.C. is valid subject to the fulfillment of the following condition provided by provision of Maharashtra fire prevention and life safety measures act 2006 and I.S. code 14435.

Conditions -

- 1) Party shall maintain in all fire fighting equipment and fire safety arrangement as per I.S. 2190 and I.S. 14435-1997.
- 2) Every six months there will be inspection of Fire Officer / Authorised agency.
- 3) Fire fitness certificate to be obtained every year from fire brigade deptt.
- 4) There should be site plan along with emergency telephone numbers like Police, Fire Brigade, Hospital, Doctors and responsible persons of the institute, should be displayed at suitable location of institute.
- 5) The necessary first aid box along with Instruments should be kept in the office.
- 6) Fire alarm device, siren / Bell / can be used for alerting the class room and audio message for the emergency evacuation.
- 7) Cautionary board such as Danger No. Smoking, Exit, fire Escape, Extinguisher, hydrant, manual call point, etc. should be displayed on the strategic location to guide the occupant in case of emergency.


**Incharge Fire Officer
Fire & Emergency Service
Municipal Council, Gondia**

FIRE SAFETY CERTIFICATE



No.

Date :

Certified that the Progressive English School (name of the building or premises) at Chulod Road, Chulod, Gondia (address) comprised of Ground basement(s) and First Floor (upper floors) owned / occupied by Progressive English School, Run by Smt. Umabai Mlp. Education Society, Gondia. (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the officers concerned of Fire Service on 05.08.2026 (date of inspection) in the presence of Mr. Niraj Kale (Asst. Fire Officer - INC) (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy class with effect from 07.08.2026 for a period of One years in accordance with rule and subject to compliance of the conditions.

Issued on 07.08.2026 at Gondia by

* Strike out whichever is not applicable.

Signature with Seal : 

Name : Incharge Fire Officer

Designation : Fire & Emergency Service
Municipal Council, Gondia

To,

The Principal
Progressive English School
Chulod Road, Chulod, Gondia

(Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled and annulled due to
..... (reasons to be recorded)

(Name and designation of the authorized signatory)